

Danish Indoor Climate Labelling



Testing and labelling criteria

Semi hard floors

3rd edition, January 2018

Reference to General labelling criteria	Property	Requirements
Clause 2	<i>Use(s)</i>	The criteria cover semi hard floorcoverings, laminates and wood floorings of treated or untreated character.
Clause 5.2	<i>Materials needed for completion</i>	<p>It should appear, whether the supplier prescribes the use of other materials at assembly and for completion, and whether these materials are included in the labelling license.</p> <p>Some products may need treatment before use or in the initial phase of the product's life span. If treatment of the product or other supplementary products are necessary or recommended by the manufacturer, it should be stated whether these products or treatments are included in the test.</p>
Clause 6.5	<i>Sampling</i>	<p>Unopened retail packages are sampled for testing whenever appropriate.</p> <p>Storage sampling of boards delivered in large pallets shall be directed to boards in the middle of the pallet.</p>
Clause 7	<i>Reference room loading factor</i>	Loading factor for floors appears from EN 16516.
Clause 7.1	<i>Test specimen preparation</i>	<p>From stacked products always discard the top and bottom piece.</p> <p>Large size boards: Cut the test specimen from the middle of the sample, excluding minimum 10 cm from all sides.</p>
Clause 8.2	<i>Maximum allowed time-value</i>	60 days